

# Energy performance certificate (EPC)

4 Buttercross Drive Little Houghton BARNSELY S72 0HS	Energy rating	Valid until: 17 July 2034
	<b>G</b>	Certificate number: 2834-7623-4300-0327-9202

Property type	Detached house
Total floor area	118 square metres

## Rules on letting this property

### ! You may not be able to let this property

This property has an energy rating of G. It cannot be let, unless an exemption has been registered. You can read [guidance for landlords on the regulations and exemptions \(https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance\)](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

Properties can be let if they have an energy rating from A to E. You could make changes to [improve this property's energy rating](#).

## Energy rating and score

This property's energy rating is G. It has the potential to be E.

[See how to improve this property's energy efficiency.](#)

Score	Energy rating	Current	Potential
92+	<b>A</b>		
81-91	<b>B</b>		
69-80	<b>C</b>		
55-68	<b>D</b>		
39-54	<b>E</b>		54 E
21-38	<b>F</b>		
1-20	<b>G</b>	18 G	

The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

- the average energy rating is D
- the average energy score is 60

# Breakdown of property's energy performance

## Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Cavity wall, as built, insulated (assumed)	Good
Roof	Pitched, 150 mm loft insulation	Good
Window	Fully double glazed	Average
Main heating	Boiler and radiators, LPG	Very poor
Main heating control	Programmer and room thermostat	Average
Hot water	From main system	Very poor
Lighting	Low energy lighting in 58% of fixed outlets	Good
Floor	Suspended, limited insulation (assumed)	N/A
Floor	To unheated space, limited insulation (assumed)	N/A
Secondary heating	Room heaters, smokeless fuel	N/A

## Primary energy use

The primary energy use for this property per year is 261 kilowatt hours per square metre (kWh/m<sup>2</sup>).

► [About primary energy use](#)

## How this affects your energy bills

An average household would need to spend **£3,713 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £1,477 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2024** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

## Heating this property

Estimated energy needed in this property is:

- 12,435 kWh per year for heating
- 2,961 kWh per year for hot water

## Impact on the environment

This property's environmental impact rating is E. It has the potential to be D.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO<sub>2</sub>) they produce each year.

## Carbon emissions

An average household produces

6 tonnes of CO<sub>2</sub>

This property produces

7.3 tonnes of CO<sub>2</sub>

---

**This property's potential production**

---

3.9 tonnes of CO2

You could improve this property's CO2 emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

# Changes you could make

► [Do I need to follow these steps in order?](#)

---

## Step 1: Increase loft insulation to 270 mm

Typical installation cost £100 - £350

Typical yearly saving £96

Potential rating after completing step 1

19 G

---

## Step 2: Floor insulation (suspended floor)

Typical installation cost £800 - £1,200

Typical yearly saving £189

Potential rating after completing steps 1 and 2

22 F

---

## Step 3: Hot water cylinder insulation

Add additional 80 mm jacket to hot water cylinder

Typical installation cost £15 - £30

Typical yearly saving £34

Potential rating after completing steps 1 to 3

22 F

---

## Step 4: Heating controls (thermostatic radiator valves)

Heating controls (TRVs)

Typical installation cost £350 - £450

Typical yearly saving £159

Potential rating after completing steps 1 to 4

25 F

---

## Step 5: Replace boiler with new condensing boiler

Typical installation cost £2,200 - £3,000

Typical yearly saving £766

Potential rating after completing steps 1 to 5

40 E

---

## Step 6: Flue gas heat recovery device in conjunction with boiler

Typical installation cost	£400 - £900
Typical yearly saving	£48
Potential rating after completing steps 1 to 6	<b>41 E</b>

## Step 7: Solar water heating

Typical installation cost	£4,000 - £6,000
Typical yearly saving	£141
Potential rating after completing steps 1 to 7	<b>45 E</b>

## Step 8: High performance external doors

Typical installation cost	£1,000
Typical yearly saving	£44
Potential rating after completing steps 1 to 8	<b>46 E</b>

## Step 9: Solar photovoltaic panels, 2.5 kWp

Typical installation cost	£3,500 - £5,500
Typical yearly saving	£475
Potential rating after completing steps 1 to 9	<b>54 E</b>

## Help paying for energy improvements

You might be able to get a grant from the [Boiler Upgrade Scheme \(https://www.gov.uk/apply-boiler-upgrade-scheme\)](https://www.gov.uk/apply-boiler-upgrade-scheme). This will help you buy a more efficient, low carbon heating system for this property.

## More ways to save energy

[Find ways to save energy in your home](#)

## Who to contact about this certificate

### Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Adrian Whitham
Telephone	07903 588 299
Email	<a href="mailto:orders@asbuiltenergysurveys.co.uk">orders@asbuiltenergysurveys.co.uk</a>

### Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

<b>Accreditation scheme</b>	Elmhurst Energy Systems Ltd
<b>Assessor's ID</b>	EES/019745
<b>Telephone</b>	01455 883 250
<b>Email</b>	<a href="mailto:enquiries@elmhurstenergy.co.uk">enquiries@elmhurstenergy.co.uk</a>

## About this assessment

<b>Assessor's declaration</b>	No related party
<b>Date of assessment</b>	3 July 2024
<b>Date of certificate</b>	18 July 2024
<b>Type of assessment</b>	▶ <a href="#">RdSAP</a>

## Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at [dluhc.digital-services@levellingup.gov.uk](mailto:dluhc.digital-services@levellingup.gov.uk) or call our helpdesk on 020 3829 0748 (Monday to Friday, 9am to 5pm).

There are no related certificates for this property.

[Help \(/help\)](#) [Accessibility \(/accessibility-statement\)](#) [Cookies \(/cookies\)](#)

[Give feedback \(https://forms.office.com/e/hUnC3Xq1T4\)](https://forms.office.com/e/hUnC3Xq1T4) [Service performance \(/service-performance\)](#)

### OGI

All content is available under the [Open Government Licence v3.0 \(https://www.nationalarchives.gov.uk/doc/open-government-licence/version/3/\)](https://www.nationalarchives.gov.uk/doc/open-government-licence/version/3/), except where otherwise stated



[ht \(https://www.nationalarchives.gov.uk/information-management/re-using-public-sector-information/uk-government-licensing-frameworkor](https://www.nationalarchives.gov.uk/information-management/re-using-public-sector-information/uk-government-licensing-frameworkor)